



1800 W Park Dr rSuite 200
Westborough, MA 01581

Phone: (508) 621-9161
www.crowncastle.com

September 18, 2025

MA - TOWN OF ASHLAND
PLANNING DEPARTMENT
101 MAIN STREET, 2ND FLOOR
ASHLAND, MA 01721


Via Email

RE: Special Permit Applications at 117 OREGON ROAD, ASHLAND, MA 01721
T-Mobile Northeast LLC 822710 / Application Number: 657779

This letter serves to confirm and clarify the question about trenching and concrete disturbance/expansion at the Planning Board's September 11 public hearing for this Special Permit Application.

Bill Blake, Construction Manager for T-Mobile has confirmed the following:

1. No existing concrete will be disturbed or altered;
2. No new concrete will be poured as part of this scope of work;
3. Hand-dug trenching is proposed for two power conduits (one 1-inch conduit and one 2-inch conduit) from the power source and will be routed around the concrete. All of this work will be done within the existing compound and the crushed stone/gravel surface will be put into place afterwards. Please see the yellow highlighted conduit paths (shown as dashed lines) on the graphic located on the following page.



We are providing this letter in an effort to respond to the Town's remaining issues with respect to the applications. We trust that you have no remaining questions on this non-discretionary review of the eligible facilities request and that the permits will be issued with no further delay. The provision of this response does not waive any rights of T-Mobile Northeast LLC under any applicable law.

Regards,
Domenica Tatasciore
Permitting Specialist, Tower Services
Crown Castle
(508) 621-9161
Domenica.Tatasciore@crowncastle.com