

SMMA

Recharge Volume and Drawdown

61 Waverly Street
Residences at Ashland1000 Massachusetts Ave.
Cambridge, MA 02138

Phone: 617.547.5400

Fax: 617.507.7885

61 Waverly St, Ashland MA

Residences at Ashland

SMMA Job No. 24142
Date: 1/19/2026
Calc by: KIC
Check by: WWP

Hydrologic	
Soil Group	Target Depth Factor (in)
A	0.60
B	0.35
C	0.25
D	0.10

Required Recharge Volume

Note: Required recharge volume is calculated utilizing DEP's "static method"

Rv = F*imp.area

	Contributing Impervious Area		Target Depth Factor (F)*	Required Volume (Rv)	Adjusted Required Volume (Rv)
	<i>sf</i>	<i>acre</i>			
Prop. Roof	HSG A	55,562	1.28	2,778	2,867
Prop. Surface Impervious Area	HSG A	165,905	3.81	8,295	8,560
Total Proposed Impervious	HSG A	221,467	5.08	11,073	11,427
Existing Impervious	HSG A	1,192	0.03	60	62
Total Required Recharge Volume	HSG A	220,275	5.06	11,014	11,365

*recharge volume required for Hydrologic Group A Soils per Mass Stormwater Manual

Recharge Volume Adjustment

Proposed New Impervious Area Within the limit of Work	5.11
Proposed Impervious Area Within the limit of Work Directed to Recharge System	4.95
Proposed Impervious Area Within the limit of Work Not Directed to Recharge System	0.13
Percent Impervious Area Directed to Recharge System	97.4%
* Ratio of New Impervious Area to Impervious Area Directed to Recharge	1.03

SMMA

Recharge Volume and Drawdown

61 Waverly Street
Residences at Ashland1000 Massachusetts Ave.
Cambridge, MA 02138

Phone: 617.547.5400

Fax: 617.507.7885

Provided Recharge Volume

	Surface Area <i>sf</i>	Recharge Provided <i>cf</i>	Notes
Subsurface System SIS-1	10,920	18,751	below outlet
Subsurface System SIS-2	7,800	10,881	below outlet
TOTAL		29,632	Combined, BMPs receive runoff from 4.95 acres impervious area or 97% of the total impervious area

Drawdown Time

	Recharge Volume <i>cf</i>	K (Rawls Rate) <i>in/hr</i>	Bottom Area <i>sf</i>	Time* <i>hr</i>
Subsurface System SIS-1	18,751	2.41	10,920	8.5
Subsurface System SIS-2	10,881	2.41	7,800	6.9

*Time = Recharge Volume / K * Bottom Area